High Speed Fuses - Square body fuse accessories



Indicator Systems (DIN 43 620)

Specifications Decription:

Typower ZILOX fuses are available with three different indicator systems.

1. Visual Indicator

The indicator situated in one cover plate is clearly visible as soon as the fuse has operated. The minimum voltage for operating the indicator is 20V.

2. Type T Indicator

The indicator is situated on one cover plate with a cover plate tag to accommodate an auxiliary switch. The minimum voltage for operating the indicator is 20V. A special low voltage indicator (1.5V) is available on request.

3. Type K Indicator

This indicator is situated on the fuse body. It is covered by an adapter for snap-on mounting of an auxiliary switch. The operating voltage of the indicator is 1.5V. As a matter of safety, the factory mounted adapter must not be removed from the fuse.

| Catalog Number | Description | Size |
|----------------|-------------|------|
| 170H0237 | Туре Т | 3 |
| 170H0235 | Туре Т | 2 |
| 170H0238 | Туре Т | 3 |
| 170H0236 | Туре Т | 3 |